

Queensland Urban Utilities Canungra Drinking Water Quality July 2010-June 2011

Aesthetic water quality

Aesthetic test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
Aluminium	89	mg/L	<0.01	0.08	0.015	0.2		Yes
Ammonia (Total, as N)	4	mg/L	<0.02	<0.02	<0.02	0.5		Yes
Chloride	11	mg/L	17	28	20	250		Yes
Colour (True)	90	PCU	<5	40.2	<5	15		Yes
Hardness (Total)	11	mg/L	53	78	62	200		Yes
Iron	89	mg/L	<0.01	4.630	0.177	0.3		Yes
pH	14	pH unit	7.7	8.2	7.8	8.5		Yes
pH (Field)	78	pH unit	7.0	8.2	7.9	8.5		Yes
Total Dissolved Solids	11	mg/L	95	141	110	500		Yes
Turbidity	90	NTU	0.12	33.40	1.31	5		Yes
Zinc	10	mg/L	<0.01	0.040	0.021	3		Yes

Queensland Urban Utilities Canungra Drinking Water Quality July 2010-June 2011

Health-related water quality

Health related test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
Barium	10	mg/L	<0.01	<0.01	<0.01		0.7	Yes
Cadmium	10	mg/L	<0.01	<0.01	<0.01		0.002	Yes
Chlorine (Free)	92	mg/L	<0.10	3.45	1.15		5	Yes
Chromium	10	mg/L	<0.010	<0.010	<0.010		0.05	Yes
Copper	10	mg/L	<0.01	0.017	<0.01		2	Yes
<i>E.coli</i>	92	MPN/100 mL	<1	<1	<1		<1	Yes
Fluoride (as F)	90	mg/L	<0.1	0.89	0.68		1.5	Yes
Lead	10	mg/L	<0.01	<0.01	<0.01		0.01	Yes
Manganese	89	mg/L	<0.01	0.060	<0.01		0.5	Yes
Nickel	10	mg/L	<0.01	<0.01	<0.01		0.02	Yes
Nitrate (as N)	11	mg/L	<0.1	0.10	0.10		50	Yes
Nitrite (as N)	7	mg/L	<0.10	0.250	<0.10		3	Yes
Trihalomethanes (Total)	11	µg/L	22	133	47		250	Yes

Queensland Urban Utilities

Canungra Drinking Water Quality July 2010-June 2011

Other water quality

Test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
Alkalinity (as CaCO ₃)	11	mg/L	47	71	60			No criterion
Chlorine (Combined)	85	mg/L	<0.10	1.65	0.34			No criterion
Chlorine (Total)	88	mg/L	<0.10	3.64	1.49			No criterion
Colour (Apparent)	90	PCU	<5	85.1	5.1			No criterion
Conductivity	92	µS/cm	137	390	197			No criterion
Dissolved Oxygen	7	mg/L	8.1	10.1	9.1			No criterion
Temperature	88	°C	15.1	30.3	21.9			No criterion

Queensland Urban Utilities

Canungra Drinking Water Quality July 2010-June 2011

Notes

- The drinking water quality data is representative of drinking water quality for each scheme for July 2010 to June 2011.
- The drinking water quality monitoring program is designed according to the ADWG 2004 and complies with statutory requirements.
- Health-related water quality complies with the ADWG 2004 that the annual 95th percentile value is less than the recommended ADWG 2004 value.
- Aesthetic water quality complies with the ADWG 2004 in that the annual 50th percentile value is less than the recommended ADWG 2004 value.
- E.coli complies with the ADWG 2004 at least 98% of scheduled samples contain no E.coli.

Definitions

ng/L	Nanograms per litre (equivalent to parts per trillion)
mg/L	Mircograms per litre (equivalent to parts per billion)
mg/L	Milligrams per litre (equivalent to parts per million)
cfu	Colony forming units
MPN	Most probable number
mS/cm	Microsiemens per centimetre
PCU	Platinum cobalt colour units
NTU	Nephelometric turbidity units
ADWG 2004	Australian Drinking Water Guidelines 2004 endorsed by the National Health & Medical Research Council