

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2010-June 2011

Aesthetic water quality

Aesthetic test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
2-methylisoborneol	12	ng/L	<2	39	13.0	5		Yes
Aluminium	12	mg/L	0.016	0.074	0.033	0.2		Yes
Ammonia (Total, as N)	12	mg/L	<0.004	0.012	<0.004	0.5		Yes
Chloride	12	mg/L	39	54	45	250		Yes
Colour (True)	12	PCU	<0.5	1.0	0.6	15		Yes
Geosmin	12	ng/L	<2	9.2	4.7	5		Yes
Hardness (Total)	12	mg/L	68	110	88	200		Yes
Iron	12	mg/L	0.012	0.120	0.037	0.3		Yes
pH	12	pH unit	7.2	7.7	7.4	8.5		Yes
Sodium	12	mg/L	32	41	37	180		Yes
Sulfate (measured as SO ₄)	12	mg/L	24	31	28	250		Yes
Total Dissolved Salts	12	mg/L	200	260	228	500		Yes
Turbidity	12	NTU	0.14	1.10	0.36	5		Yes
Zinc	12	mg/L	<0.001	0.012	0.009	3		Yes

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2010-June 2011

Health-related water quality

Health related test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
Barium	12	mg/L	0.021	0.029	0.024		0.7	Yes
Bromodichloromethane	12	µg/L	17	27	21		250	Yes
Bromoform	12	µg/L	<2	3	2		250	Yes
Cadmium	12	mg/L	<0.001	<0.001	<0.001		0.002	Yes
Chlorine (Free)	50	mg/L	0.18	2.40	1.19		5	Yes
Chlorodibromomethane	12	µg/L	9	16	12		250	Yes
Chloroform	12	µg/L	17	51	32		250	Yes
Chromium	12	mg/L	<0.001	<0.001	<0.001		0.05	Yes
Copper	12	mg/L	0.002	0.006	0.003		2	Yes
Dichloroacetic Acid	12	µg/L	14	37	22		100	Yes
<i>E.coli</i>	51	cfu/100 mL	<1	<1	<1		<1	Yes
Fluoride (as F)	12	mg/L	0.67	0.89	0.79		1.5	Yes
Lead	12	mg/L	<0.001	0.001	<0.001		0.01	Yes
Manganese (mg/L)	12	mg/L	<0.001	0.062	0.011		0.5	Yes
Nickel	12	mg/L	<0.001	<0.001	<0.001		0.02	Yes
Nitrate (as N)	12	mg/L	0.02	0.11	0.07		50	Yes
Nitrite (as N)	12	mg/L	<0.002	0.003	<0.002		3	Yes
Trichloroacetic Acid	12	µg/L	11	29	17		100	Yes
Trihalomethanes (Total)	12	µg/L	50	91	67		250	Yes

Queensland Urban Utilities

Kilcoy Drinking Water Quality July 2010-June 2011

Other water quality

Test description	No of tests	Units	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2004
Alkalinity (as CaCO ₃)	12	mg/L	60	80	71			No criterion
Bromide	12	mg/L	0.010	0.061	0.034			No criterion
Bromochloroacetic Acid	12	µg/L	<10	14	10			No criterion
Calcium	12	mg/L	13	21	17			No criterion
Chlorate	12	mg/L	<0.01	0.02	<0.01			No criterion
Chlorine (Combined)	47	mg/L	0.10	0.80	0.35			No criterion
Chlorine (Total)	50	mg/L	0.55	2.80	1.53			No criterion
Conductivity	12	µS/cm	310	400	356			No criterion
Dibromoacetic Acid	12	µg/L	<10	<10	<10			No criterion
Haloacetic Acids (Total)	10	µg/L	<60	80	<60			No criterion
Langelier Index	12		-1.20	-0.42	-0.87			No criterion
Magnesium	12	mg/L	9	14	11			No criterion
Monobromoacetic Acid	12	µg/L	<5	<5	<5			No criterion
Monochloroacetic Acid	12	µg/L	<5	<5	<5			No criterion
Nitrite and Nitrate (as N)	12	mg/L	0.020	0.110	0.066			No criterion
Potassium	12	mg/L	1.9	2.4	2.2			No criterion
Silica	12	mg/L	11	17	14			No criterion
Silicon	12	mg/L	5	8	7			No criterion
Total Organic Carbon	12	mg/L	2.2	3.5	2.9			No criterion
Total Sulfur (as S)	12	mg/L	8.0	10.0	9.2			No criterion

Queensland Urban Utilities

Kilcoy Drinking Water Quality July 2010-June 2011

Notes

- The drinking water quality data is representative of drinking water quality for each scheme for July 2010 to June 2011.
- The drinking water quality monitoring program is designed according to the ADWG 2004 and complies with statutory requirements.
- Health-related water quality complies with the ADWG 2004 that the annual 95th percentile value is less than the recommended ADWG 2004 value.
- Aesthetic water quality complies with the ADWG 2004 in that the annual 50th percentile value is less than the recommended ADWG 2004 value.
- E.coli complies with the ADWG 2004 at least 98% of scheduled samples contain no E.coli.

Definitions

ng/L	Nanograms per litre (equivalent to parts per trillion)
mg/L	Mircograms per litre (equivalent to parts per billion)
mg/L	Milligrams per litre (equivalent to parts per million)
cfu	Colony forming units
MPN	Most probable number
mS/cm	Microsiemens per centimetre
PCU	Platinum cobalt colour units
NTU	Nephelometric turbidity units
ADWG 2004	Australian Drinking Water Guidelines 2004 endorsed by the National Health & Medical Research Council